

Approved For Release 2003/04/29 : CIA-RDP84-00780R000400200007-1

TRANSMITTAL SLIP		DATE
TO: 		
ROOM NO.	BUILDING	
7D-02	HQ	
REMARKS:		
<div style="border: 1px solid black; width: 100px; height: 30px; display: inline-block;"></div> - Trans Div. - '78 advise memo and '77 and material being requisitioned '78. H		
FROM: CIA Asst. Safety Officer		
ROOM NO.	BUILDING	F
1C-4801	HQ	
FORM NO. 241 1 FEB 55		
REPLACES FORM 36-8 WHICH MAY BE USED.		
GPO : 1957-O-439445 (47)		

Approved For Release 2003/04/29 : CIA-RDP84-00780R000400200007-1

25X1

3 DEC 1964

MEMORANDUM FOR: Chief, Transportation Division, CI

SUBJECT : Fire Fighting Equipment for Helicopter Landings,
Headquarters Building

Pursuant to our telephone conversation, the equipment listed below should be procured to provide minimum fire protection for helicopter landing and take-off at the Headquarters Building.


a. Two hundred feet (200 feet) of standard two and one half inch (2½ inch) fire hose equipped with standard size fire department connections. Equip with combination straight stream and fog nozzle.

b. Fifty feet (50 feet) of one and one half inch (1½ inch) standard fire hose equipped with combination straight stream and fog nozzle. All connectors to be standard fire department sizes.

c. Adapter to connect two and one half inch (2½ inch) hose to one and one half inch (1½ inch) hose.

d. Take-up reel for hose.

e. Two (2) one hundred and fifty pound (150 pound) Dry Chemical wheeled fire extinguishers with wheels for outdoor use.



CIA Assistant Safety Officer

25X1